



Remark:

- 1、 The foundation and the support of center sump are at the same level.
- 2、 The height deviation should less than 1/4".
- 3、 Final foundation design must be determined considering the pump's NPSHR.
- 4、 Location of anchors is approximate and final location must be verified on-site by the installer.



PROJECT / MODEL

MCC-04B FOUNDATION

TITLE

MESAN COOLING TOWER

| | | | |
|-------------|-------------|------------|-------------|
| DRAWN BY | DESIGNED BY | CHECKED BY | APPROVED BY |
| KING | MING | MING | ISA |
| SCALE | FILE NAME | DATE | |
| | | 2014-01-06 | |
| DRAWING NO. | | REVISION | |
| MCC-04B-F | | 01 | |