



The height of the foundation should be set according to the water outlet pipe diameter.

- Remark:
- 1、 The foundation and the support of center sump are at the same level.
  - 2、 The height deviation should be less than 1/4".
  - 3、 Final foundation design must be determined considering the pump's NPSHR.
  - 4、 Location of anchors is approximate and final location must be verified on-site by the installer.



PROJECT / MODEL  
**MCC-06B**  
**FOUNDATION**

TITLE  
**MESAN COOLING TOWER**

|             |             |            |             |
|-------------|-------------|------------|-------------|
| DRAWN BY    | DESIGNED BY | CHECKED BY | APPROVED BY |
| KING        | MING        | MING       | ISA         |
| SCALE       | FILE NAME   | DATE       |             |
|             |             | 2014-01-05 |             |
| DRAWING NO. | MCC-06-F    | REVISION   | 01          |

SECTION A-A

Cement foundation

water outlet

≈ 400mm  
 [≈ 15 3/4"]

300mm  
 [11 3/4"]

3900mm  
 [12'-9 1/2"]

1200mm  
 [3'-11 1/4"]

3900mm  
 [12'-9 1/2"]

1200mm  
 [3'-11 1/4"]

1200mm  
 [3'-11 1/4"]