



The height of the foundation should be set according to the water outlet pipe diameter.

A-A

- Remark:
- 1、The foundation and the support of center sump are at the same level.
 - 2、The height deviation should less than 1/4" .
 - 3、Final foundation design must be determined considering the pump's NPSHR.
 - 4、The operating weight is 4553lbs .

				
PROJECT / MODEL				
MKT-125				
FOUNDATION				
TITLE				
MESAN COOLING TOWER				
DRAWN BY				
DESIGNED BY		CHECKED BY		APPROVED BY
xin	xin	Alice		Isa
SCALE		FILE NAME		DATE
		DRAWING NO.		2012-05-03
				REVISION
				01