


Remark:

- 1、The foundation and the support of center sump are at the same level.
- 2、The height deviation should less than 1/4".
- 3、Final foundation design must be determined considering the pump's NPSHR.
- 4、The operating weight is 265lbs.

			
PROJECT / MODEL			
MKT-6			
FOUNDATION			
TITLE			
MESAN COOLING TOWER			
DRAWN BY	DESIGNED BY	CHECKED BY	APPROVED BY
xin	xin	Alice	Isa
SCALE	FILE NAME		DATE
			2012-05-03
	DRAWING NO.		REVISION
			01