



- Remark:**
- 1、 The foundation and the support of center sump are at the same level.
 - 2、 The height deviation should be less than 1/4" .
 - 3、 Final foundation design must be determined considering the pump's NPSHR.
 - 4、 Location of anchors is approximate and final location must be verified on-site by the installer .
 - 5、 The cooling tower foundation is designed and manufactured by customer.



PROJECT / MODEL

**MXC-01
FOUNDATION**

TITLE

MESAN COOLING TOWER

DRAWN BY DESIGNED BY CHECKED BY APPROVED BY

MING

MING

ISA

ISA

SCALE

FILE NAME

DATE

2012.12.01

DRAWING NO.

MXC-01-F

REVISION

01

