



Ø1/2"X5" anchor bolts (16 places)
By customer

- Remark:**
- 1、 The foundation and the support of center sump are at the same level.
 - 2、 The height deviation should be less than 1/4".
 - 3、 Final foundation design must be determined considering the pump's NPSHR.
 - 4、 Location of anchors is approximate and final location must be verified on-site by the installer.
 - 5、 The cooling tower foundation is designed and manufactured by customer.



PROJECT / MODEL

**MXC-04
FOUNDATION**

TITLE

MESAN COOLING TOWER

DRAWN BY DESIGNED BY/CHECKED BY/APPROVED BY

MING MING ISA ISA

SCALE FILE NAME

DATE

2012.12.01

DRAWING NO.

REVISION



MXC-04-F

01