



**Remark:**

- 1、 The foundation and the support of center sump are at the same level.
- 2、 The height deviation should less than 1/4" .
- 3、 Final foundation design must be determined considering the pump's NPSHR.
- 4、 Location of anchors is approximate and final location must be verified on-site by the installer .
- 5、 The cooling tower foundation is designed and manufactured by customer.



PROJECT / MODEL

**MXC-06  
FOUNDATION**

TITLE

**MESAN COOLING TOWER**

DRAWN BY	DESIGNED BY	CHECKED BY	APPROVED BY
MING	MING	ISA	ISA
SCALE	FILE NAME	DATE	REVISION
		2012.12.01	01
	DRAWING NO.		
	MXC-06-F		