



Remark:

- 1、 The foundation and the support of center sump are at the same level.
- 2、 The height deviation should less than 1/4".
- 3、 Final foundation design must be determined considering the pump's NPSHR.

			
PROJECT / MODEL			
MXL-03C FOUNDATION			
TITLE			
MESAN COOLING TOWER			
DRAWN BY	DESIGNED BY	CHECKED BY	APPROVED BY
XIN	XIN	ISA	ISA
SCALE	FILE NAME	DATE	
		2013.12.20	
	DRAWING NO.	REVISION	
	MXL-03C-F	01	