



- Remark:
- 1、 The foundation and the support of center sump are at the same level.
  - 2、 The height deviation should be less than 1/4".
  - 3、 Final foundation design must be determined considering the pump 's NPSHR



PROJECT MODEL  
**MXR-KM-B2-11**  
**FOUNDATION**

TITLE  
**MESAN COOLING TOWER**

DRAWN BY Xln	DESIGNED BY Xln	CHECKED BY Alice	APPROVED BY Isa
SCALE	FILE NAME	DATE	
		2012-05-03	
DRAWING NO.		REVISION	
		01	