



- Remark:
- 1、 The foundation and the support of center sump are at the same level.
  - 2、 The height deviation should be less than 1/4".
  - 3、 Final foundation design must be determined considering the pump's NPSHR



PROJECT MODEL

MXR-KM-C5-15  
FOUNDATION

TITLE

MESAN COOLING TOWER

DRAWN BY Xln DESIGNED BY Xln CHECKED BY Alice APPROVED BY Isa

SCALE FILE NAME DATE 2012-05-03

DRAWING NO. REVISION 01

